



RURAL DRINKING WATER & SANITATION DEPARTMENT, GoK
Bengaluru Urban Divisional Laboratory-Banashankari, Bangalore-560070.
NABL Accredited Laboratory Bangalore urban

TEST REPORT					
Address of the sampling location :- EAST BANGALORE SCHOOL No.76/2, Gundur Village, Bidarahalli Hobli, Virgonagar Post Bangalore East, Bangalore-560049.				Report date: 24/01/2025	
				Report Number: 0008	
				Reference: TRF	
				Sample code: 0008	
				Date of Sample collection: 22/01/2025	
				Analysis start date: 22/01/2025	
				Analysis completion date: 23/01/2025	
				Sample quantity: 1 Liter	
Sample Particulars: Borewell water					
Sl. No	Test	Results	Acceptable Limit IS 10500 : 2012 RA:2018	Permissible Limit IS 10500 : 2012 RA:2018	Protocol
Description: Colourless liquid					
1	pH Value @25°C Temp	7	6.5 – 8.5	No relaxation	IS 3025 (Part-11) : 2022
2	Specific Conductance, µS/cm @25°C Temp	540	-	-	IS 3025 (Part-14) : 2013
3	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5 & 6):2018
4	Colour, Hazen Units	<1.0	5	15	IS 3025 (Part-4) :2021
5	Turbidity, NTU	0.4	1	5	IS 3025 (Part-10) : 2023
6	Total Dissolved Solids, mg/l @180°C	340	500	2000	IS 3025 (Part-16) : 2023
7	Alkalinity as CaCO ₃ , mg/l	168	200	600	IS 3025 (Part-23) : 2023
8	Total Hardness as CaCO ₃ , mg/l	148.1	200	600	IS 3025 (Part-21) : 2009
9	Calcium as Ca, mg/l	36.9	75	200	IS 3025 (Part-40) : 1991
10	Magnesium as Mg, mg/l	13.6	30	100	IS 3025 (Part-46) : 2023
11	Chloride as Cl, mg/l	37.7	250	1000	IS 3025 (Part-32) : 1988
12	Sulphate as SO ₄ , mg/l	16	200	400	IS 3025 (Part-24) : 2022
13	Fluoride as F, mg/l	0.2	1	1.5	APHA 24 th Edition
14	Nitrate as NO ₃ , mg/l	3.8	45	No relaxation	APHA 24 th Edition
15	Iron as Fe, mg/l	Nil	1	No relaxation	IS 3025 (Part-53) : 2003
Remark: The above given sample conforms to the acceptable limits as per IS 10500:2012 drinking water specifications for the above mentioned parameters only.					
Analysed by: <i>Megha K.S</i> Senior Analyst/Junior Analyst			Authorized Signatory: <i>Pavithra B.S</i> Technical Manager: Pavithra B.S		



RDWSD/WQMSP/TeR/01

Note:

- 1) The above results relate only to the sample tested.
- 2) The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- 3) **Traceability:** Traceability of measurements is established using CRMs traceable to National/International standards.
- 4) Samples will be discarded after 15 days from the date of report generation.
- 5) Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01

---END---